

ADDENDUM #1

Manchester-by-the-Sea, MA
2023 Water Main Improvements Project

Date of Addendum: September 15, 2023
Bid Due Date: September 20, 2023 @ 1pm

GENERAL UPDATES:

- Contractors must maintain traffic on Walker Road- this is a dead end neighborhood.
- If houses are bypassed all hoses must be equipped with pressure reducing valves.
- On Walker Rd., if any pressure reducing valves are installed at meters in houses, they will be replaced in-kind with the new service installations using the service allowance item.
- Generally, the watermains included in this project have a service pressure around 110 PSI.

CONTRACTOR QUESTIONS:

Question #1: Does this project have to take place over the winter?

Response: Yes, Walker Road (base bid) must be completed over the winter months. There are other Town projects in the area influenced by the completion of this project and must be completed over the winter as noted, assumed to be completed February 2024. The Contractor shall cross under the existing water mains and services to maintain existing main potable water service during the construction of the new main over the winter months and minimal to no bypass will be necessary.

Alternate bid items have more flexible winter shut down schedules.

CHANGES TO SPECIFICATIONS:

None

ATTACHMENTS:

Placeholder list, September 15, 2023